

PORTO DUBAI

EC HARRIS

TT

LAYAN BENCH GROUP PVT. LTD.

DEC

CUNDALL

SEC

arabtec

MATERIAL SUBMITTAL APPROVAL

Ref.: ATC-MAR-S-G-035

ACTION REQ. BY - DEC

Sub-Contractor Ref.:

Rev.: 0

Date: 13/09/2008

1. DESCRIPTION:

Threaded CBT Rebar Coupler For R.C.C. Structures.

From - M/s Bautech international, LLC - 1st Supplier.

Attachments -

1) Prequalification With Technical Data

2) Photograph of Sample.

3) Sample: 16mm,20mm,25mm & 32mm Dia.

Area of Application :All Villas

Drawing Ref. : N/a

Specification Ref. : -

Attach all relevant technical literature marked to identify relevant descriptions, current Test Certificates, samples as appropriate.

2. MANUFACTURER/SUPPLIER:

Subcontractor : Bautech international, LLC

Address : P.O. Box 27922, Dubai - UAE

Local Agent : Bautech international, LLC

3. DELIVERY:

Country of Origin : UAE

Availability ☒ Locally Manufactured

Delivery : Ex-works/ Total Duration

Estimated Time of Arrival on Site

Program : Date Material Required on Site

Latest Date for Order

PORTO DUBAI CIRCULATION

| NAME        | ACT | INFO | CNTR |
|-------------|-----|------|------|
| ED          |     |      |      |
| PM          |     |      |      |
| CM1         |     |      |      |
| CM2         |     |      |      |
| COM         |     |      |      |
| TECH        |     |      |      |
| PLAN        |     |      |      |
| QA          |     |      |      |
| STUD        |     |      |      |
| SAP         |     |      |      |
| ADMIN       |     |      |      |
| STORE       |     |      |      |
| TIME OFFICE |     |      |      |
| MATL. ENG.  |     |      |      |
| POS. CONT.  |     |      |      |
| OVERSEAS    |     |      |      |

Building : All

Floor : All

B.O.Q. Ref. No. :

Standards : British Standards

PORTO DUBAI

13 SEP 2008

TRANSMITTED

We certify that the above submitted items have been reviewed in detail and are correct and in strict conformity with the contract drawings and specifications except as otherwise stated; also that the material sources indicated above have been reviewed in detail and that they will supply the submitted items in conformity with the above and deliver same timely.

Authorized Contractor Representative : Tara Muddappa

Title : Project Manager

Signature :

4. Consultant's Comments

Approved as Noted.

1) Samples should be tested in presence of DEC.

2) Installation should be done by specialist & skilled workers

5. Engineer Representative's Comments

Response supplied by:

Copy: EC Harris/ DEC/ Layan/ SEC/ Cundall/ Arabtec/ Wagher/ Other consultant/s

Response Date: dd/mm/yy

27/12/08

PORTO DUBAI

27 DEC 2008

RECEIVED

MATERIAL SUBMITTAL APPROVAL

Sub-Contractor Ref. :

Ref. : ATC-MAR-S-G-016

Rev. : 0

Date : 21/08/2008

1. DESCRIPTION :

Pressed CBT Rebar Coupler For Piles And Concrete Structures, From M/s. Bautech International LLC.

Attachments -

1) Technical Data.

2) Drawing No. PD/V3A/Zet/17/S-1001 Rev.0 & PD/V2A/ZET/RW/S-1095 Rev.0

3) Some Samples of 16mm, 20mm, 25mm and 32mm

Area of Application : All Villas

Building : All

Floor : All

Drawing Ref. : PD/V3A/Zet/17/S-1001-0 & PD/V2A/ZET/RW/S-1095-0

B.O.Q. Ref. No. :

Specification Ref. : -

Standards : British Standards

Attach all relevant technical literature marked to identify relevant description, current Test Certificates, samples as appropriate.

2. MANUFACTURER/SUPPLIER :

Company Name : Bautech International, LLC

Address : P.O. Box 27922, Dubai, UAE

Local Agent : Bautech International, LLC

3. DELIVERY :

Country of Origin UAE (Dubai)

Availability

☒ Locally Manufactured

☐ Overseas

Delivery

Ex-works/ Total Duration

Estimated Time of Arrival on Site

Program

Date Material Required on Site

Latest Date for Order

We certify that the above submitted items have been reviewed in detail and are correct and in strict conformity with the contract drawings and specifications except as otherwise stated; also that the material sources indicated above have been reviewed in detail and that they will supply the submitted items in conformity with the above and deliver same timely.

Authorized Contractor Representative : Tara Muddappa

Title : Project Manager

Signature :

PORTO DUBAI

21 AUG 2008

TRANSMITTED

4. Consultant's Comments

Contractor must strictly follow the Manufacturer's instruction and call consultant for witnessing the procedures

5. Engineer Representative's Comments

Dinesh, Borkar

Response supplied by:

Copy: EC Harris/ DEC/ Layan/ SEC/ Cundall/ Arabtec/ Wagner/ Other consultant/s

Response Date: dd/mm/yy

PORTO DUBAI

CIRCULATION

| NAME | ACT | INFO | CNTR |
|------|-----|------|------|
| EC   |     |      |      |
| PM   |     |      |      |
| CM   |     |      |      |
| COM  |     |      |      |
| TECH |     |      |      |
| MR   |     |      |      |
| PLAN |     |      |      |
| IRU  |     |      |      |
| MIN  |     |      |      |
| SEC  |     |      |      |
| OFF  |     |      |      |

☐ Approved

☐ Approved as Noted

☐ Revise and Resubmit

☐ Rejected

☐ Sample Required

☐ Tests Required

☐ Additional Info. Required

☐ Manufacturer's Guarantee Required